

Low Salinity Units – up to 2000 mg/l TDS salinity

Permeate Output (m3/hr)	8	4	2	1	0.63	0.4
Recovery *	75% +	75% +	75%	Up to 75%	Up to 70%	Up to 65%
Feedwater Salinity (approx)	2,000 mg/l	2,000 mg/l	2,000 mg/l	2,000 mg/l	2,000 mg/l	2,000 mg/l
Power Requirement HP Motor	7.5 kW 3 ph	4 kW 3ph	4 kW 3ph	2.2 kW 1ph	1.5 kW 1ph	<1.0 kW 1ph
Auto flush system	Yes	Yes	Yes	Yes	Yes	Optional
Online Conductivity monitoring	Yes	Yes	Yes	Yes	Yes	Optional
316 stainless steel feed pump	Yes	Yes	Yes	Yes	Yes	Yes
Cleaning tank and CIP clean system	Yes	Yes	Yes	Yes	Yes	Optional
Space Requirements	8m x 3m	8m x 3m	6m x 3m	4.0m x 3m	4.0m x 3m	3m x 2m

*Recovery dependent upon a range of factors